

## Pool Underground Electric Inspection

Effective 1/1/2005 all swimming pools will have an additional inspection added to the pool permit. Underground electric (outside of the pool deck) area will now require an inspection. This inspection is to be called in with the Deck Steel inspection. The following depth requirements will apply.

Rigid metal conduit ----- 6”

Rigid metal conduit or PVC (installed under a residential driveway) ----- 18”

PVC conduit (GFCI protected conductors) ----12”

PVC conduit ----- 18”

PVC conduit (low voltage) ----- 6”

There shall not be more than four quarter bends (360 degrees) between pull points. Kicks and 90’s will be counted, but long sweeping conduit runs will not be counted in this calculation.

---

This handout is for informational purposes only and should not be relied on in place of official regulations and/or policies. The CITY OF PLANO makes no representations, guarantees, or warranties as to the accuracy, completeness, currency, or suitability of the information provided via the handout. Customers and citizens are personally responsible for complying with all local, state and federal laws pertaining to projects within the city. Copies of the CITY OF PLANO adopted codes and Zoning Ordinances can be found on the city website at [www.plano.gov](http://www.plano.gov) or at the CITY OF PLANO Municipal Center at 1520 Avenue K, Plano, Texas.

